



Dubai World Central International Airport



Contract Ref: JXB1/DB/220

Material Submittal

Cargo Terminal Building

Contract: Phase 1

Ref. No: MS-AMB-LAKSHMI-AR-088

Rev.1

To the Engineer: Dar Al-Handasah

Date: 26.01.09

MATERIAL DESCRIPTION (One Item Only Per Form) As Specification [ x ] Alternative [ ]

Title : Special Function Door – Blast Resistant Door | Sample : - Not applicable

Description : 2 Hours fire rated Blast Resistant Door (Size 3m x 2.40m) – Model : Customised door (UL certified)

- Attach all relevant technical literature marked to identify relevant descriptions, current test certificate, samples etc.
- Attach a certificate stating compliance with Contract requirements
- Highlight any element of contractual non-compliance in this submittal

Drawing Ref: - 0-002-0, 6-013-0 (Refer attached approved shop drawing submittal ref AR-120 Rev.1)

Planned Date for applicable submittal for: -

Date:

Specification Ref: - 08340

1. O & M Manual - Catalogues

Feb '09

BOQ Ref: - N/A

2. DCA Training

N/A

International Standards Ref: - TM5-1300 standard

3. Specified /recommended spare parts

N/A

4. Warranties and Guarantees

Attached

Manufacturer / Supplier

1). Door : M/s Samhoun Co. Ltd. Korea

Locally Manufactured : No

AGCC Manufactured : N/A

2) Electrical Components (Automatic door): M/s FAAC Italy

Production Period : N/A

Delivery Ex-works : N/A

Total Delivery Time : Ready stock

Overland : N/A

Sea Freight : N/A

Total Freight : N/A

Local Agent : Lakshmi Metal Tech. LLC Dubai.

Jebel Ali Airport  
Cargo Terminal Building  
28 JAN 2009  
TRANSMITTED

Programme: -

Contractor's QA / QC Manager:

Contractor's Authorized Signature:

Date required on Site: - Dec '08

*Arallil*

*Arallil*

Expected date of arrival on Site: - Dec '08

Engineer's Comments :-

- 1) No objection for the proposed door swing leaf automated system
- 2) Submit country of origin certificate and spare parts.
- 3) Comply with door weight.
- 4) Contractor to ensure coordination with the SACs system provider to ensure compatibility and proper interfacing as per contract requirements.
- 5) UL Label to be provided for Fire rating.
- 6) Certificate for Blast Resistance to provide from ITA
- 7) Colours to match with adjacent *class / approved scheme*
- 8) Country of Origin not meeting Spec Sec. 01600/2.1. Propose through Value Eng

Signed/Resident Engineer  
9.2.09

Status	Code 1	Code 2	Code 3	Code 4
	Work may proceed	Revise and Resubmit Work may proceed	Revise & Resubmit Work may not proceed	Review not required Work may proceed



Chief Resident Engineer

*P/P*

CC: DCA  
TTS

Jebel Ali Airport  
Cargo Terminal Building  
10 FEB 2009  
RECEIVED

Date: - 9/2/09

Important: Permission to proceed does not relieve contractor from full compliance with contractual obligations