

TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE

DATE

17-May-11

TRANSMITTAL NO.


08 11 13.00 31 - 3.1

(Read instructions on reverse side prior to initiating this form)

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS *(This section will be initiated by the contractor)*

| | | | |
|---|--|------------------------------------|---|
| TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610 | FROM: KRIMA CONSTRUCTION CORP. | CONTRACT NO: 2009MFH0220 | CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3 |
| SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31 | PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA. | | CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL |

| ITEM NO | DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.) | MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8) | NO OF COPIES | CONTRACT REFERENCE DOCUMENT | | FOR CONTRACTOR USE CODE | VARIATION (See instruction No.6) | FOR CE USE CODE |
|---------|---|--|--------------|-----------------------------|-------------------|-------------------------|----------------------------------|-----------------|
| | | | | SPEC PARA NO. | DRAWING SHEET NO. | | | |
| a. | b. | c. | d. | e. | f. | g. | h. | i. |
| 7 | STEEL FIRE RATED DOOR | Drawing & Data | 5 | 2.7 | A-603 ~ 605 | A | | B |
| a. | TYPE "B" THERMAL INSULATED METAL DOOR W/ METAL FRAME | | | | | | | |
| | 45Min Fire Rated, U.L Labeled Class "B", #18GA. Level II, Heavy Duty, | | | | | | | |
| | Formed-In-Place Polyurethane Core, Impact And Thermal Resistance | | | | | | | |
| | Mechanically Interlocked, Hemmed Vertical Edge Seam, Full Flush Design | | | | | | | |
| | #16GA. Steel Frame Knocked Down Unit, Double Rabbit | | | | | | | |
| | Concrete Wall Type, 4-Existing Opening Anchor (#EO/S6) Per Each Jamb | | | | | | | |
| | Hot-Dipped Galvanized Steel, Conforming To ASTM A924 & A568 | | | | | | | |
| | One Coat OF Oven-Cured Natural color Primer Paint, Conform with ANSIA250.10 | | | | | | | |
| | Cont'd | | | | | | | |



REMARKS

I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated

CHO, JUN KI / CQC

NAME AND SIGNATURE OF CONTRACTOR

SECTION II-APPROVAL ACTION

| | | |
|---------------------------------------|---|-----------------|
| ENCLOSURES RETURNED(List by Item No.) | NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY <i>M. Benke con</i> | DATE 6/20/11 |
|---------------------------------------|---|-----------------|

| | | |
|--|--------------------------|--|
| TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small> | DATE 17-May-11 | TRANSMITTAL NO. 08 11 13.00 31 - 3.1 |
|--|--------------------------|--|

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

| | | |
|---|--|--|
| TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610 | FROM: KRIMA CONSTRUCTION CORP. | CONTRACT NO: 2009MFH0220 |
| SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31 | PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA. | CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3 CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL |

| ITEM NO | DESCRIPTION OF ITEM SUBMITTED <small>(Type size, model number/etc.)</small> | MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. <small>(See instruction no.8)</small> | NO OF COPIES | CONTRACT REFERENCE DOCUMENT | | FOR CONTRACTOR USE CODE | VARIATION <small>(See instruction No.6)</small> | FOR CE USE CODE |
|---------|--|---|--------------|-----------------------------|-------------------|-------------------------|--|-----------------|
| | | | | SPEC PARA NO. | DRAWING SHEET NO. | | | |
| a. | b. | c. | d. | e. | f. | g. | h. | i. |
| | Frame Size : 45mm Face & 146mm Depth w/ 13mm Backbend | | | | | | | |
| | Slim Trim Vision Kit for 100mm x 600mm Visible Size w/ Fire Rated Wire Glass | | | | | | | |
| | R. Opening Size : 1000mmW x 2150mmH | | | | | | | |
| | Door Size : 900mmW x 2100mmH x 44.5mmTHK RHR-3Sets | | | | | | | |
| | Model : SAMHOON "FG" Type Door | | | | | | | |
| | Steel Frame With DSN Wall Anchor Type | | | | | | | |
| | MFR : SAMHOON Co., Ltd. | | | | | | | |
| | P.O.U: STAIR#2 TO CORRIDOR-1(106) DOOR No.:D-4 | | | | | | | |
| | STAIR#2 TO CORRIDOR-2(209) DOOR No.:D-8 | | | | | | | |
| | STAIR#2 TO CORRIDOR-3(303) DOOR No.:D-19 | | | | | | | |

| | |
|---------|---|
| REMARKS | I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right; margin-top: 20px;"> CHO, JUN KI / CQC NAME AND SIGNATURE OF CONTRACTOR </div> |
|---------|---|

SECTION II-APPROVAL ACTION

| | | |
|---------------------------------------|---|---|
| ENCLOSURES RETURNED(List by Item No.) | NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY <div style="text-align: center; margin-top: 10px;"></div> | DATE <div style="text-align: center; margin-top: 10px;">6/20/11</div> |
|---------------------------------------|---|---|

| | | |
|--|--------------------------|--|
| TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small> | DATE 17-May-11 | TRANSMITTAL NO. 08 11 13.00 31 - 3.1 |
|--|--------------------------|--|

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

| | | | |
|---|--|------------------------------------|---|
| TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610 | FROM: KRIMA CONSTRUCTION CORP. | CONTRACT NO: 2009MFH0220 | CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3 |
|---|--|------------------------------------|---|

| | | |
|---|--|---|
| SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31 | PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA. | CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL |
|---|--|---|

| ITEM NO | DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.) | MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8) c. | NO OF COPIES d. | CONTRACT REFERENCE DOCUMENT | | FOR CONTRACTOR USE CODE g. | VARIATION (See instruction No.6) h. | FOR CE USE CODE i. |
|---------|---|--|--------------------|-----------------------------|-------------------------|-------------------------------|--|-----------------------|
| | | | | SPEC PARA NO. e. | DRAWING SHEET NO. f. | | | |
| a. | b. | | | | | | | |
| b. | TYPE "B" THERMAL INSULATED METAL DOOR W/ METAL FRAME | | | | | | | |
| | 45Min Fire Rated, U.L Labeled Class "B", #18GA. Level II, Heavy Duty, | | | | | | | |
| | Formed-In-Place Polyurethane Core, Impact And Thermal Resistance | | | | | | | |
| | Mechanically Interlocked, Hemmed Vertical Edge Seam, Full Flush Design | | | | | | | |
| | #16GA. Steel Frame Knocked Down Unit, Double Rabbet | | | | | | | |
| | Concrete Wall Type, 4-Existing Opening Anchor (#EO/S6) Per Each Jamb | | | | | | | |
| | Hot-Dipped Galvanized Steel, Conforming To ASTM A924 & A568 | | | | | | | |
| | One Coat OF Oven-Cured Natural color Primer Paint, Conform with ANSIA250.10 | | | | | | | |
| | Cont'd | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

| | |
|---------|--|
| REMARKS | <p>I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated</p> <p style="text-align: center;"><i>[Signature]</i> CHO, JUN KI / CQC</p> <p style="text-align: center;">NAME AND SIGNATURE OF CONTRACTOR</p> |
|---------|--|

SECTION II-APPROVAL ACTION


| | | |
|---------------------------------------|--|------------------------|
| ENCLOSURES RETURNED(List by Item No.) | NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY <i>[Signature]</i> | DATE <i>6/20/11</i> |
|---------------------------------------|--|------------------------|

| | | |
|--|--------------------------|--|
| TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small> | DATE 17-May-11 | TRANSMITTAL NO. 08 11 13.00 31 - 3.1 |
|--|--------------------------|--|


SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

| | | | |
|---|---|------------------------------------|--|
| TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610 | FROM: KRIMA CONSTRUCTION CORP. | CONTRACT NO: 2009MFH0220 | CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3 |
| SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31 | PROJECT TITLE AND LOCATION: CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA. | | CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOVT. APPROVAL |

| ITEM NO. | DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.) | MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no. 8) | NO OF COPIES | CONTRACT REFERENCE DOCUMENT | | FOR CONTRACTOR USE CODE | VARIATION (See instruction No. 6) | FOR CE USE CODE |
|----------|---|---|--------------|-----------------------------|-------------------|-------------------------|-----------------------------------|-----------------|
| | | | | SPEC PARA NO. | DRAWING SHEET NO. | | | |
| a. | b. | c. | d. | e. | f. | g. | h. | i. |
| | Frame Size : 45mm Face & 146mm Depth w/ 13mm Backbend | | | | | | | |
| | R. Opening Size : 1000mmW x 2150mmH | | | | | | | |
| | Door Size : 900mmW x 2100mmH x 44.5mmTHK RHR-1Set | | | | | | | |
| | Model : SAMHOON "FD" Type Door | | | | | | | |
| | Steel Frame With DSN Wall Anchor Type | | | | | | | |
| | MFR : SAMHOON Co., Ltd. | | | | | | | |
| | P.O.U: EXT. TO OPEN OFFICE-1(202)(208) DOOR No.:D-10 | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

| | |
|---------|--|
| REMARKS | I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right;">  CHO, JUN KI / CQC NAME AND SIGNATURE OF CONTRACTOR </div> |
|---------|--|

SECTION II-APPROVAL ACTION

| | | |
|---------------------------------------|---|------------------------|
| ENCLOSURES RETURNED(List by Item No.) | NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY  | DATE 6/20/11 |
|---------------------------------------|---|------------------------|


| | | |
|--|--------------------------|--|
| TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small> | DATE 17-May-11 | TRANSMITTAL NO. 08 11 13.00 31 - 3.1 |
|--|--------------------------|--|

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)


| | | | |
|---|--|------------------------------------|--|
| TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610 | FROM: KRIMA CONSTRUCTION CORP. | CONTRACT NO. 2009MFH0220 | CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3 |
|---|--|------------------------------------|--|

| | | |
|---|---|--|
| SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31 | PROJECT TITLE AND LOCATION: CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAЕ NAVAL BASE, KOREA. | CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL |
|---|---|--|

| ITEM NO | DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.) | MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no. 8) c. | NO OF COPIES d. | CONTRACT REFERENCE DOCUMENT | | FOR CONTRACTOR USE CODE g. | VARIATION (See instruction No. 6) h. | FOR CE USE CODE i. |
|---------|--|---|--------------------|-----------------------------|-------------------------|-------------------------------|---|-----------------------|
| | | | | SPEC PARA NO. e. | DRAWING SHEET NO. f. | | | |
| a. | b. | | | | | | | |
| c. | TYPE "C" METAL FIRE RATED DOOR W/ METAL FRAME 60Min Fire Rated, U.L Labeled Class "B", #18GA. Level II, Heavy Duty, Formed-In-Place Ceramicwool Core, Impact And Thermal Resistance Mechanically Interlocked, Hemmed Vertical Edge Seam, Full Flush Design #16GA. Steel Frame Knocked Down Unit, Double Rabbet Concrete Wall Type, 4-Existing Opening Anchor (#EO/S6) Per Each Jamb Hot-Dipped Galvanized Steel, Conforming To ASTM A924 & A568 One Coat OF Oven-Cured Natural color Primer Paint, Conform with ANSIA250.10 Cont'd | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

| | |
|---------|--|
| REMARKS | I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right;">  CHO, JUN KI / CQC NAME AND SIGNATURE OF CONTRACTOR </div> |
|---------|--|

SECTION II-APPROVAL ACTION

| | | |
|---------------------------------------|--|------------------------|
| ENCLOSURES RETURNED(List by Item No.) | NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY  con | DATE 6/20/11 |
|---------------------------------------|--|------------------------|


| | | |
|--|--------------------------|--|
| TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small> | DATE 17-May-11 | TRANSMITTAL NO. 08 11 13.00 31 - 3.1 |
|--|--------------------------|--|

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)


| | | | |
|---|--|------------------------------------|--|
| TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610 | FROM: KRIMA CONSTRUCTION CORP. | CONTRACT NO: 2009MFH0220 | CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3 |
|---|--|------------------------------------|--|

| | | |
|---|---|---|
| SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31 | BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA. | CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOVT. APPROVAL |
|---|---|---|

| ITEM NO | DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.) | MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8) c. | NO OF COPIES d. | CONTRACT REFERENCE DOCUMENT | | FOR CONTRACTOR USE CODE g. | VARIATION (See instruction No.6) h. | FOR CE USE CODE i. |
|---------|--|--|--------------------|-----------------------------|-------------------------|-------------------------------|--|-----------------------|
| | | | | SPEC PARA NO. e. | DRAWING SHEET NO. f. | | | |
| a. | b. | | | | | | | |
| | Frame Size : 45mm Face & 146mm Depth w/ 13mm Backbend | | | | | | | |
| | Slim Trim Vision Kit for 100mm x 600mm Visible Size w/Fire Glass | | | | | | | |
| | R. Opening 1000mmW x 2150mmH | | | | | | | |
| | Door Size 900mmW x 2100mmH x 44.5mmTHK RHR-2Sets LHR-1Set | | | | | | | |
| | Model : SAMHOON "FG" Type Door | | | | | | | |
| | Steel Frame With DSN Wall Anchor Type | | | | | | | |
| | MFR : SAMHOON Co., Ltd. | | | | | | | |
| | P.O.U: CORRIDOR-1(106) TO STAIR#1 DOOR No.:D-5 | | | | | | | |
| | STAIR#1 TO CORRIDOR-2(209)) DOOR No.:D-11 | | | | | | | |
| | STAIR#1 TO CORRIDOR-3(303)) DOOR No.:D-20 | | | | | | | |

| | |
|---------|--|
| REMARKS | I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right;">  CHO, JUN KI / CQC NAME AND SIGNATURE OF CONTRACTOR </div> |
|---------|--|

SECTION II-APPROVAL ACTION

| | | |
|---------------------------------------|---|------------------------|
| ENCLOSURES RETURNED(List by Item No.) | NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY  | DATE 6/20/11 |
|---------------------------------------|---|------------------------|

| | | |
|--|--------------------------|--|
| TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small> | DATE 17-May-11 | TRANSMITTAL NO. 08 11 13.00 31 - 3.1 |
|--|--------------------------|--|

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

| | | |
|---|--|------------------------------------|
| TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610 | FROM: KRIMA CONSTRUCTION CORP. | CONTRACT NO: 2009MFH0220 |
|---|--|------------------------------------|

CHECK ONE

THIS IS A NEW TRANSMITTAL

THIS IS A RE-SUBMITTAL OF
TRANSMITTAL 08 11 13.00 31 - 3

CHECK ONE: THIS TRANSMITTAL IS
FOR FIO GOVT. APPROVAL

| | |
|---|--|
| SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31 | PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAЕ NAVAL BASE, KOREA. |
|---|--|

| ITEM NO | DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.) | MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8) | NO OF COPIES | CONTRACT REFERENCE DOCUMENT | | FOR CONTRACTOR USE CODE | VARIATION (See instruction No.6) | FOR CE USE CODE |
|---------|---|--|--------------|-----------------------------|-------------------|-------------------------|----------------------------------|-----------------|
| | | | | SPEC PARA NO. | DRAWING SHEET NO. | | | |
| a. | b. | c. | d. | e. | f. | g. | h. | i. |
| d. | TYPE "C" METAL FIRE RATED DOOR W/ METAL FRAME | | | | | | | |
| | 20Min Fire Rated, U.L Labeled Class "B", #18GA. Level II, Heavy Duty, | | | | | | | |
| | Formed-In-Place Ceramicwool Core, Impact And Thermal Resistance | | | | | | | |
| | Mechanically Interlocked, Hemmed Vertical Edge Seam, Full Flush Design | | | | | | | |
| | #16GA. Steel Frame Knocked Down Unit, Double Rabbet | | | | | | | |
| | Concrete Wall Type, 4-Existing Opening Anchor (#EO/S6) Per Each Jamb | | | | | | | |
| | Hot-Dipped Galvanized Steel, Conforming To ASTM A924 & A568 | | | | | | | |
| | One Coat OF Oven-Cured Natural color Primer Paint, Conform with ANSIA250.10 | | | | | | | |
| | Cont'd | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

| | |
|---------|--|
| REMARKS | <p>I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated</p> <p style="text-align: right;"><i>[Signature]</i> CHO, JUN KII / CQC</p> <p style="text-align: center;">NAME AND SIGNATURE OF CONTRACTOR</p> |
|---------|--|

SECTION II-APPROVAL ACTION

| | | |
|---------------------------------------|--|------------------------|
| ENCLOSURES RETURNED(List by Item No.) | NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY <i>[Signature]</i> con | DATE 6/20/11 |
|---------------------------------------|--|------------------------|

| | | |
|--|--------------------------|--|
| TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small> | DATE 17-May-11 | TRANSMITTAL NO. 08 11 13.00 31 - 3.1 |
|--|--------------------------|--|


SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

| | | |
|---|---|------------------------------------|
| TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610 | FROM: KRIMA CONSTRUCTION CORP . | CONTRACT NO: 2009MFH0220 |
|---|---|------------------------------------|


CHECK ONE
 THIS IS A NEW TRANSMITTAL
 THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3

| | | |
|---|--|--|
| SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31 | PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN-N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA. | CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL |
|---|--|--|

| ITEM NO | DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.) | MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8) | NO OF COPIES | CONTRACT REFERENCE DOCUMENT | | FOR CONTRACTOR USE CODE | VARIATION (See instruction No.6) | FOR CE USE CODE |
|---------|---|--|--------------|-----------------------------|-------------------|-------------------------|----------------------------------|-----------------|
| | | | | SPEC PARA NO. | DRAWING SHEET NO. | | | |
| a. | b. | c. | d. | e. | f. | g. | h. | i. |
| | Frame Size : 45mm Face & 146mm Depth w/ 13mm Backbend | | | | | | | |
| | R. Opening Size : 1000mmW x 2150mmH | | | | | | | |
| | Door Size : 900mmW x 2100mmH x 44.5mmTHK RHR-2Sets | | | | | | | |
| | Model : SAMHOON "FD" Type Door | | | | | | | |
| | Steel Frame With DSN Wall Anchor Type | | | | | | | |
| | MFR : SAMHOON Co., Ltd. | | | | | | | |
| | P.O.U: CORRIDOR-2(209) TO COMM.ROOM(208) DOOR No.:D-12 | | | | | | | |
| | CORRIDOR-3(303) TO COMM.ROOM(302)) DOOR No.:D-21 | | | | | | | |

| | |
|---------|---|
| REMARKS | <p>I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated</p> <p style="text-align: center;"> CHO, JUN KI / CQC</p> <p style="text-align: center;">NAME AND SIGNATURE OF CONTRACTOR</p> |
|---------|---|

SECTION II-APPROVAL ACTION

| | | |
|---------------------------------------|---|------------------------|
| ENCLOSURES RETURNED(List by Item No.) | NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY  | DATE 6/20/11 |
|---------------------------------------|---|------------------------|

| | | |
|--|--------------------------|--|
| TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small> | DATE 17-May-11 | TRANSMITTAL NO. 08 11 13.00 31 - 3.1 |
|--|--------------------------|--|

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

| | | | |
|---|--|------------------------------------|---|
| TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610 | FROM: KRIMA CONSTRUCTION CORP. | CONTRACT NO: 2009MFH0220 | CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3 |
|---|--|------------------------------------|---|

| | | |
|---|--|---|
| SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31 | PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA. | CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL |
|---|--|---|

| ITEM NO | DESCRIPTION OF ITEM SUBMITTED <small>(Type size, model number/etc.)</small> | MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. <small>(See instruction no.8)</small> | NO OF COPIES | CONTRACT REFERENCE DOCUMENT | | FOR CONTRACTOR USE CODE | VARIATION <small>(See instruction No.6)</small> | FOR CE USE CODE |
|---------|--|---|--------------|-----------------------------|-------------------|-------------------------|--|-----------------|
| | | | | SPEC PARA NO. | DRAWING SHEET NO. | | | |
| a. | b | c. | d. | e. | f. | g. | h. | i. |
| e. | TYPE "C" METAL FIRE RATED DOOR W/ METAL FRAME | | | | | | | |
| | 45Min Fire Rated, U.L Labeled Class "B", #18GA. Level II, Heavy Duty, | | | | | | | |
| | Formed-In-Place Ceramicwool Core, Impact And Thermal Resistance | | | | | | | |
| | Mechanically Interlocked, Hemmed Vertical Edge Seam, Full Flush Design | | | | | | | |
| | #16GA. Steel Frame Knocked Down Unit, Double Rabbet | | | | | | | |
| | Dry Wall Type, 1/8" Increments with Steel Stud Anchor | | | | | | | |
| | Hot-Dipped Galvanized Steel, Conforming to ASTM A924 & A568 | | | | | | | |
| | One Coat OF Oven-Cured Natural color Primer Paint, Conform with ANSIA250.10 | | | | | | | |
| | Cont'd | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

| | |
|----------------------------------|--|
| REMARKS | I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right; padding-right: 20px;"> CHO, JUN KI / CQC</div> |
| NAME AND SIGNATURE OF CONTRACTOR | |

SECTION II-APPROVAL ACTION

| | | |
|---------------------------------------|--|------------------------|
| ENCLOSURES RETURNED(List by Item No.) | NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY <div style="text-align: center; padding: 10px;"> M. Bueh con</div> | DATE 6/20/11 |
|---------------------------------------|--|------------------------|


| | | |
|--|--------------------------|--|
| TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small> | DATE 17-May-11 | TRANSMITTAL NO. 08 11 13.00 31 - 3.1 |
|--|--------------------------|--|

SECTION I-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

| | | | |
|---|--|------------------------------------|--|
| TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610 | FROM: KRIMA CONSTRUCTION CORP. | CONTRACT NO: 2009MFH0220 | CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3 |
|---|--|------------------------------------|--|

| | |
|---|--|
| SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31 | PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA. |
|---|--|

| ITEM NO | DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.) | MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8) c. | NO OF COPIES d. | CONTRACT REFERENCE DOCUMENT | | FOR CONTRACTOR USE CODE g. | VARIATION (See instruction No.6) h. | FOR CE USE CODE i. |
|---------|---|--|--------------------|-----------------------------|-------------------------|-------------------------------|--|-----------------------|
| | | | | SPEC PARA NO. e. | DRAWING SHEET NO. f. | | | |
| a. | b. | | | | | | | |
| | Frame Size : 45mm Face & 205mm Depth w/ 13mm Backbend | | | | | | | |
| | R. Opening Size : 1000mmW x 2150mmH | | | | | | | |
| | Door Size : 900mmW x 2100mmH x 44.5mmTHK LH-1Set | | | | | | | |
| | Model : SAMHOON "FD" Type Door | | | | | | | |
| | Steel Frame With DSH Steel Stud with Gypsum Board Type | | | | | | | |
| | MFR : SAMHOON Co., Ltd. | | | | | | | |
| | P.O.U: OFFICE(202) TO STORAGE(206)) DOOR No.:D-18 | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

| | |
|---------|---|
| REMARKS | I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right;">  CHO JUN KI / CQC NAME AND SIGNATURE OF CONTRACTOR </div> |
|---------|---|

SECTION II-APPROVAL ACTION

| | | |
|---------------------------------------|---|------------------------|
| ENCLOSURES RETURNED(List by Item No.) | NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY  | DATE 6/20/11 |
|---------------------------------------|---|------------------------|

| | | | |
|--|-------------------------------------|----------------------------------|---------------------------------------|
| TRANSMITTAL OF SHOP DRAWINGS, EQUIPMENT DATA, MATERIAL SAMPLES, OR MANUFACTURER'S CERTIFICATES OF COMPLIANCE | | DATE 06/15/2011 | TRANSMITTAL NO. 08 11 13.00 31-3.1 |
| PROJECT TITLE | CY07 ROKC In-Kind Bachelor Quarters | CONTRACT NO. 2009-MFH-0220 NA | PAGE 1 of 1 |
| LOCATION | Chinhae Naval Base, Korea | | |

| <i>Item</i> | <i>Description</i> | <i>Variation</i> | <i>QA Code</i> |
|-------------|-----------------------|------------------|----------------|
| 7 | STEEL FIRE RATED DOOR | No | B |

SECTION III - GOVERNMENT REVIEW REMARKS

1. Fire rated label shall be permanently affixed at the factory to frame and to the hinge edge of the door.
 2. Fire rated label shall be metal with raised letters, and shall bear the name or file number of the door and frame manufacturer.
 3. All surfaces of doors and frames shall be thoroughly cleaned, chemically treated and factory primed with a rust inhibiting coating as specified in SDI A250.8.
- CYK