



KUWAIT NATIONAL PETROLEUM COMPANY
PROJECTS DEPARTMENT - II

P.O Box 69, Safat 13001, Kuwait Tel (965) 23884230, Fax no. (965) 23280714

Facsimile Transmission Cover Sheet

Date: 1 MAR 2015

Ref. No.: KNPC/DAELIM/SHFP/HO-F-15-1766

From: A/Team Leader - Projects Coordination(Gr.VI) - PD II

	Company	Attention	Fax No.
To	M/s. Daelim Industrial Co. Ltd. Korea	Mr. Song Myeung-Suck Project Manager	0082-22096- 6100

SULPHUR HANDLING FACILITIES (REVAMP AND NEW) PROJECT
(SHFP) AT MAA REFINERY

CONT. No.: CA/CSPD/0022

Blast Door Testing Requirement

(00)Number of pages to follow the cover sheet

Response
Required

Yes√ | No

Hashem

Hashem AL-Mahmeed

SPECIAL INSTRUCTIONS OR COMMENTS

Reference to your Fax no. DAELIM/ KNPC/SHFP/HO-F-15-0908 dated 3rd March 2015 on the above subject, Daelim shall note the followings:

1. It is very clearly stated in the contract document that Proprietary Manufacturer must have shop testing facility to carry out the test for the designed blast pressure before shipping. Hence, all items must be **tested in the shop before shipping** and there is no ambiguity in the contract.
2. Daelim to note that specific testing requirement before shipping for all items are clearly mentioned in the contract. Hence, testing of 1 bigger size door is not acceptable. At the same time, Daelim should also note that purpose of the testing is to ensure that there should not be ANY DAMAGE and integrity must be guaranteed for the basic reason of functioning of these items even after the actual blast scenario, as these items are not supposed to be replaced after actual blast.

Therefore, Daelim is requested to adhere to the testing of all items before shipping as per contract.

Regards,

IF COPY IS ILLEGIBLE OR INCOMPLETE PLEASE SEND MESSAGE BACK TO

FAX No. : 23280714

CONFIDENTIALITY STATEMENT

This facsimile contains private or other sensitive information and is intended solely for the recipient named above. If you are not the intended recipient, you should hold this message in confidence and be aware that any disclosure, copying, distribution or use of this information is prohibited. (1) Do not use this information or disclose to others. (2) Please notify the sender by telephone. (3) Please return this message via fax, to the sender named above. We appreciate your co-operation with this request.

NYO/AKS
cc: file



KUWAIT NATIONAL PETROLEUM COMPANY
PROJECTS DEPARTMENT - II

SULPHUR HANDLING FACILITIES (REVAMP AND NEW) PROJECT
(SHFP) AT MAA REFINERY
CONTRACT No.: CA/CSPD/0022

TR. NO.: KNPC/DAELIM/SHFP/HO-T-15-3421

DATE: 27 JAN 2015

DOCUMENT TRANSMITTAL

To: M/s. Daelim Industrial Co. Ltd.
Korea

cc:

Attn: Mr. Song Myeung-Suck
Project Manager

Fax.: 0082-22096-6100

KNPC comments on the following document(s) as listed below are hereby transmitted for your information / action:

Total Number of pages including the cover sheet: (01)

Ref.: DAELIM /KNPC/SHFP/HO-T-15-4126

Dated: 19/01/15

Recd. Date: 19/01/15

Document ID	Rev. No.	Description / Title	Appr. Stat.
VP-43-703-001-A01-ALL-SK-005	A	Shop Drawing	R1
VP-43-703-001-A01-ALL-C-008	A	Structural Analysis and Design	R1

Legend : A1-Approved, A2-Approved with comments, A 3-Not approved,
R1-Reviewed-no comments, R-2 : Reviewed with comments

Remarks:

Note: Any review, comments, agreement or approval by the Company shall in no way relieve the Contractor from its Obligations to fulfill all the requirements of the Contract or affect the Company's guarantee rights.

NYO / AKS

cc: File / Site office

SENT BY:

Hashem

Hashem Al-Mahmeed

A/Team Leader-Projects Coordn.(Gr.VI)-PDII



KUWAIT NATIONAL PETROLEUM COMPANY
PROJECTS DEPARTMENT - II

SULPHUR HANDLING FACILITIES (REVAMP AND NEW) PROJECT
(SHFP) AT MAA REFINERY
CONTRACT No.: CA/CSPD/0022

TR. NO.: KNPC/DAELIM/SHFP/HO-T-15-3436

DATE: 28 JAN 2015

DOCUMENT TRANSMITTAL

To: M/s. Daelim Industrial Co. Ltd.
Korea

cc:

Attn: Mr. Song Myeung-Suck
Project Manager

Fax.: 0082-22096-6100

KNPC comments on the following document(s) as listed below are hereby transmitted for your information / action:

Total Number of pages including the cover sheet: (01)

Ref.: DAELIM /KNPC/SHFP/HO-T-15-4087

Dated: 15/01/15

Recd. Date:15/01/15

Document I'D	Rev. No.	Description / Title	Appr. Stat.
VP-43-703-001-A01-ALL-S-001	A	Vendor Print Index & Schedule	R1
VP-43-703-001-A01-ALL-P-004	A	Work Schedule	R1

Legend : A1-Approved, A2-Approved with comments, A 3-Not approved,
R1-Reviewed-no comments, R-2 : Reviewed with comments

Remarks:

Note: Any review, comments, agreement or approval by the Company shall in no way relieve the Contractor from its Obligations to fulfill all the requirements of the Contract or affect the Company's guarantee rights.

NYO / AKS / BKR
cc: File / Site office

SENT BY:

Hashem Al-Mahmeed

A/Team Leader-Projects Coordn.(Gr.VI)-PDII





KUWAIT NATIONAL PETROLEUM COMPANY
PROJECTS DEPARTMENT - II

SULPHUR HANDLING FACILITIES (REVAMP AND NEW) PROJECT
(SHFP) AT MAA REFINERY
CONTRACT No.: CA/CSPD/0022

TR. NO.: KNPC/DAELIM/SHFP/HO-T-15-3437

DATE: 28 JAN 2015

DOCUMENT TRANSMITTAL

To: M/s. Daelim Industrial Co. Ltd.
Korea
Attn: Mr. Song Myeung-Suck
Project Manager
Fax: 0082-22096-6100

cc:

KNPC comments on the following document(s) as listed below are hereby transmitted for your information / action:

Total Number of pages including the cover sheet: (02)

Ref.: DAELIM /KNPC/SHFP/HO-T-15-4088

Dated: 15/01/15

Recd. Date:15/01/15

Document I'D	Rev. No.	Description / Title	Appr. Stat.
VP-43-703-001-A01-ALL-P-002	A	Inspection Test Plan	R2
VP-43-703-001-A01-ALL-P-003	A	WPS & PQR	R2
VP-43-703-001-A01-ALL-P-010	A	ASTM F 2247 Test Procedure of Blast Resistant Door (Quality Control Procedure)	R1

Legend : A1-Approved, A2-Approved with comments, A 3-Not approved,
R1-Reviewed-no comments, R-2 : Reviewed with comments

Remarks:

Note: Any review, comments, agreement or approval by the Company shall in no way relieve the Contractor from its Obligations to fulfill all the requirements of the Contract or affect the Company's guarantee rights.

AKS
NYO / AKS/ BKR
cc: File / Site office

SENT BY:

Hashem

Hashem Al-Mahmeed

A/Team Leader-Projects Coordn.(Gr.VI)-PDII

KNPC – PCGVI - PD II
SULPHUR HANDLING FACILITIES (REVAMP AND NEW) PROJECT
(SHFP) AT MAA REFINERY
CONTRACT No.: CA/CSPD/0022

DOCUMENT REVIEW / COMMENT FORM

K.N.P.C'S RESPONSE TR. NO. KNPC/DAELIM/SHFP/HO-T-15-3437
 CONTRACTOR'S TR. NO. DAELIM /KNPC/SHFP/HO-T-15-4088

TR. REC'D DATE :15/01/2015

COMMENT NO.	DOC. REF.	KNPC'S COMMENTS	ACTION CODE (*)	CONTRACTOR'S RESPONSE (**)
1	VP-43-703-001-A01-ALL-P-002	Inspection Test Plan a) PMI shall be applicable for all materials and welds for materials other than CS also ferrite test for the welds in line with approved procedure SHFP-PGP-012. W- for Daelim and RW for KNPC b) Activity #6: NDE activities shall be W for Daelim.		
2	VP-43-703-001-A01-ALL-P-003	WPS & PQR -The following are required to review the document a) WPS register/summary shall be included along with detail weld map having the details of thickness also. b) Applicable PQR shall be attached particularly for SS materials. c) Applicable code shall be indicated the WPS & PQR.		

ACTION CODES: A – CONCUR

N – NON-CONCUR

(*) To be completed by Contractor

(**) To be completed by Contractor if Action code is "N"