

CUI

ATTENTION

Use this space to indicate categories, limited dissemination controls, special instructions, points of contact, etc., if needed.

ATTENTION

All individuals handling this information are required to protect it from unauthorized disclosure.

Handling, storage, reproduction, and disposition of the attached document(s) must be in accordance with 32 CFR Part 2002 and applicable agency policy.

Access to and dissemination of Controlled Unclassified Information shall be allowed as necessary and permissible to any individual(s), organization(s), or grouping(s) of users, provided such access or dissemination is consistent with or in furtherance of a Lawful Government Purpose and in a manner consistent with applicable law, regulations, and Government-wide policies.

Standard Form 901 (11-18)
Prescribed by GSA/ISOO | 32 CFR 2002

CUI

TRANSMITTAL OF SHOP DRAWINGS, EQUIPMENT DATA MATERIAL SAMPLES, OR MANUFACTURER'S CERTIFICATES OF COMPLIANCE	CONTRACT NO. W912ER19C0004	PAGE 2 of 2
---	-------------------------------	----------------

PROJECT TITLE Camp Arifjan, Kuwait	DATE 09/25/2022	TRANSMITTAL NO. 08 39 53-1.2
LOCATION Unaccompanied Officer's Quarters		

Item	Description	Variation	QA Code
2	Blast Resistant Doors Korean Manufacturer	No	C

SECTION III - GOVERNMENT REVIEW REMARKS

Code-C- Approved except as noted below

1. Submit the full hardware list. The list is missing the door threshold and heavy-duty special hinge.
2. Per the Door schedule Door type BB shall be 1600 X 2150, the shop drawings submitted should be revised to reflect this.