


TRANSMITTAL OF SHOP DRAWINGS, EQUIPMENT DATA, MATERIAL SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <i>(Read instructions on the reverse side prior initiating this form)</i>	DATE 17 Feb. 2013	TRANSMITTAL NO. 08 11 13.00 31-2.5
---	----------------------	---------------------------------------

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS *(This section will be initiated by the contractor)*

TO: K-C PMC	FROM: SAMSUNG CONSORTIUM	CONTRACT NO: 1009556	CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RESUBMITTAL OF TRANSMITTAL 08 11 13.00 31-2.4
----------------	-----------------------------	-------------------------	---

SPECIFICATION SEC.NO.(Cover only one section with each transmittal) 08 11 13.00 31	PROJECT TITLE AND LOCATION CY08 YRP PN A08Y903, ELEMENTARY SCHOOL USAG HUMPHREYS, KOREA	CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL
---	---	--

ITEM NO.	DESCRIPTION OF ITEM SUBMITTED (Type size,model number/etc.)	MFG OR CONTR, CAT.,CURVE DRAWING OR BROCHURE NO. (See instruction no.8)	NO OF COPIES	CONTRACT REFERENCE DOCUMENT		FOR CONTRACTOR USE CODE	VARIATION (See instruction No.6)	FOR CE USE CODE
				SPEC PARA NO.	DRAWING SHEET NO.			
a.	b.	c.	d.	e.	f.	g.	h.	i.
20	TYPE-F, INSULATED STL HOLLOW CORE W/STL FRAME, 900*2100*45, STC-33, V/GLASS 150X800 33 STC RATING #14GA, Level III, Heavy Duty, Sound Insulation Materials, Polyure Foam Mechanically Interlocked, Hemmed Vertical Edge Seam, Full Flush Design #14GA. Steal Frame Knocked Down Unit, Concrete Wall Type 4-Existing Opening Anchor Per Each Jamb Hot-Dipped Galvanized Steel, Conforming To KS D 3506 Slim Trim Vision Kit for 150mm x 800mm Visible Size, Laminated Glass; 6mm+PVB 0.76 Frame Size:44mm Face & 160mm Depth w/15mm Backbend R.Opening Size; 1000mmW x 2150mmH, Door Size: 900mmW x 2100mmH MFR: Samhoo Co., Ltd. POU: Door No.:D161	Product Data	3	2.1/2.7	AE610~AE615 AE621~AE627 AE633~AE635 AE620 AE629~AE630a	"A"		A



REMARKS	I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated. CQCSM: KIM, KWANGNAM NAME AND SIGNATURE OF CONTRACT
---------	--

SECTION II-APPROVAL ACTION

ENCLOSURES RETURNED(List by Item No.)	NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY <i>CMS Ma...</i>	DATE 18 Feb 2013
---------------------------------------	--	---------------------